




Janice K. Brewer
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY

1110 West Washington Street • Phoenix, Arizona 85007
(602) 771-2300 • www.azdeq.gov



Henry R. Darwin
Director



Salt River Power
Attn: Dan Bevier
Mail Station CGS600
P.O. Box 1018
St. Johns, AZ 85936

per 4477

Re: Extension Request for Compliance with Mercury Air Toxics Standard (MATS),
Coronado Generating Station, Permit No. 52639


Dear Mr. Bevier,

The Arizona Department of Environmental Quality (ADEQ) is in receipt of your letter dated July 10, 2013, regarding the request for a one year extension for compliance with 40 CFR § 63, Subpart UUUUU – NESHAP: Coal and Oil Fired Electric Utility Steam Generating Units (MATS) for the Coronado Generating Station Units 1 and 2. Based upon the issues complicating the installation of the retrofit emissions technology, including:

1. Difficulties in implementing current control technologies that minimize collateral impacts such as equipment corrosion;
2. Increased time needed to test alternative technologies such as Gore Carbon Sorbent Polymer technology; and
3. Time needed to implement the chosen control technology;

ADEQ hereby approves the request for a one year extension of compliance with the MATS, pursuant to 40 CFR § 63.9(c) and § 63.6(i), with a final compliance achievement date of April 16, 2016. The extension is contingent upon the submittal of a permit revision request to incorporate the conditions of the extension of compliance into the Title V permit; a compliance schedule indicating the dates by which each step towards compliance will be reached; and progress reports that indicate the status of each compliance step, submitted within 30 days of each step noted in the compliance schedule. If you have any questions, please feel free to contact me at (602) 771-2288.

Sincerely,



Eric C. Massey, Director
Air Quality Division

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ 85701
(520) 628-6733